Energy performance certificate (EPC)

Apartment 1, 32, Gardiner Street Antrim Belfast BT13 2GT Energy rating

 Valid until:
 9 February 2031

 Certificate number:
 9200-3001-3302-5649-4204


Property type Ground-floor flat

Total floor area 58 square metres

Energy rating and score

This property's energy rating is B. It has the potential to be B.

See how to improve this property's energy efficiency.



The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in Northern Ireland:

the average energy rating is D the average energy score is 60

Breakdown of property's energy performance

Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Walls	Average thermal transmittance 0.23 W/m²K	Very good
Floor	Average thermal transmittance 0.18 W/m²K	Very good
Windows	High performance glazing	Very good
Main heating	Boiler and radiators, mains gas	Good
Main heating control	Time and temperature zone control	Very good
Hot water	From main system	Good
Lighting	Low energy lighting in all fixed outlets	Very good
Air tightness	Air permeability 2.5 m³/h.m² (as tested)	Very good
Roof	(other premises above)	N/A
Secondary heating	None	N/A

Primary energy use

The primary energy use for this property per year is 98 kilowatt hours per square metre (kWh/m2).

How this affects your energy bills

An average household would need to spend £345 per year on heating, hot water and lighting in this property. These costs usually make up the majority of your energy bills.

You could **save £0 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2021** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

Impact on the environment

This property's environmental impact rating is B. It has the potential to be B.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO2) they produce each year.

Carbon emissions

An average household produces

6 tonnes of CO2

This property produces This property's	1.1 tonnes of CO2 1.1 tonnes of CO2
potential production	

You could improve this property's CO2 emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

Changes you could make

The assessor did not make any recommendations for this property.

Help paying for energy improvements

You might be able to get a grant from the <u>Boiler Upgrade Scheme (https://www.gov.uk/apply-boiler-upgrade-scheme)</u>. This will help you buy a more efficient, low carbon heating system for this property.

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Seamus O'Kane
Telephone	08700 850490
Email	enquiries@elmhurstenergy.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd	
Assessor's ID	EES/005128	
Telephone	01455 883 250	
Email	enquiries@elmhurstenergy.co.uk	
About this assessment		
Assessor's declaration	No related party	
Date of assessment	10 February 2021	
Date of certificate	10 February 2021	
Type of assessment	SAP	